

### Notice Inviting Quotations

Sealed Quotation is hereby re-invited on behalf of Director, Punjab Engineering College, Sector-12, Chandigarh for the following items and will be opened in the office of the undersigned on dated 16.07.2018 at 3:30 P.M. The quotations will be received up to 3:00 P.M.

**Name of Work: Repair & Renovation work in faculty room (Prof. Rajesh Kanda) in Mech. Department in Punjab Engineering College, Sector-12, Chandigarh.**

SCHEDULE OF QUANTITY					
Sr. No.	Description	QTY	Unit	Rate to be quoted by firms	Amount
1.	Providing and fixing percolated galvanized iron profile sheets (size, shape and pitch of corrugation as approved by Engineer-in-charge) 0.50 mm (+ 0.05 %) total coated thickness with zinc coating 120 grams per sqm as per IS: 277, in 240 mpa steel grade, 5-7 microns epoxy primer on both side of the sheet and polyester top coat 15-18microns. Sheet should have protective guard film of 25 microns minimum to avoid scratches during transportation and should be supplied in single length up to 12 meter or as desired by Engineering- charge. The sheet shall be fixed using self drilling /self tapping screws of size (5.5x 55 mm) with EPDM seal, complete upto any pitch in horizontal/ vertical or curved surfaces, excluding the cost of purlins, rafters and trusses and including cutting to size and shape wherever required.	25	Sqm		
2.	Providing and fixing tiled false ceiling of specified materials of size 595x595 mm in true horizontal level, suspended on inter locking metal grid of hot dipped galvanized steel sections ( galvanized @ 120 grams/ sqm, both side inclusive) consisting of main "T" runner with suitably spaced joints to get required length and of size 24x38 mm made from 0.30 mm thick (minimum) sheet, spaced at 1200 mm center to center and cross "T" of size 24x25 mm made of 0.30 mm thick (minimum) sheet, 1200 mm long spaced between main "T" at 600 mm center to center to form a grid of 1200x600 mm and secondary cross "T" of length 600 mm and size 24x25 mm made of 0.30 mm thick (minimum) sheet to be interlocked at middle of the 1200x600 mm panel to form grids of 600x600 mm and wall angle of size 24x24x0.3				

	mm and laying false ceiling tiles of approved texture in the grid including, required cutting/making, opening for services like diffusers, grills, light fittings, fixtures, smoke detectors etc. Main "T" runners to be suspended from ceiling using GI slotted cleats of size 27 x 37 x 25 x1.6 mm fixed to ceiling with 12.5 mm dia and 50 mm long dash fasteners, 4 mm GI adjustable rods with galvanized butterfly level clips of size 85 x 30 x 0.8 mm spaced at 1200 mm center to center along main T, bottom exposed width of 24 mm of all T-sections shall be pre-painted with polyester paint, all complete for all heights as per specifications, drawings and as directed by Engineer-in-charge.				
	GI Metal Ceiling Lay in perforated Tegular edge global white color tiles of size 595x595 mm and 0.5 mm thick with 8 mm drop; made of GI sheet having galvanizing of 100 gms/sqm (both sides inclusive) and 20% perforation area with 1.8 mm dia holes and having NRC (Noise Reduction Coefficient ) of 0.5, electro statically polyester powder coated of thickness 60 microns (minimum), including factory painted after bending and perforation, and backed with a black Glass fiber acoustical fleece.	24	Sqm		

**Terms & Conditions:**

1. The work shall be carried out as per CPWD specification and as per direction of the Engineer-in-charge.
2. No T&P shall be issued to the agency.
3. The rates shall be inclusive of GST.
4. Time allowed 01 months.
5. Nothing extra shall be paid on any other account.

University Engineer

**Endst. No.**

**Dated**

Copy of the above is forwarded to the following:

1. Registrar
2. Chairman Estate & Works
3. Head, Computer Centre, with a request to upload on the Institute website
4. P.A to Director for kind information please
5. Notice Board