Punjab Engineering College, Sector-12, Chandigarh (Deemed to be University)

No. PEC/EO/2022/2708 Dated:

0 8 FEB 2022

Notice Inviting Quotations

Sealed Quotation are hereby invited on behalf of Director, Punjab Engineering College, Secor-12, Chandigarh on percentage rate basis for the following work and will be opened in the office of the undersigned on dated 11.02.2022 at 3:30 p.m. The quotations will be received on or before 11.02.2022 upto 3:00 p.m.

NAME OF WORK: -

SUPPLY AND ERECTION OF LED 70-WATT STREET LIGHT FITTINGS ON THE EXISTING PCC POLES IN THE STREET OF HOUSE NO 664 TO 659, 651 TO 658 AT PUNJAB ENGINEERING COLLEGE, SECTOR-12, CHANDIGARH.

LNo	Description SCHEDULE OF WORK	Oty	Unit	Rate	Amount
	the state of the s				
1.	Supply and erection of LED 70 watt street light 5700K on the exisiting PCC pole on GI pipe bracket including connection testing commissioning etc make	8	each	7738	61904
	Wipro Model-LR02-781-XXX-57-G2 Philips BRP032 LED CW SLR GR PSU	100			
	Trilux-10175361 LSL 7000-860 ET	· .			
2.	Fabrication supply and erection of GI pipe bracket made of 1 mtr long GI pipe1 *1/2" dia bending in suitable shape and fixing on existing PCC pole for LED light fiture inleuding tools and plants such as Ghori, etc	8	each	734	5872
3.	Fabrication supply and erection of MS flat clamp made from 40*5mm MS flat suitable to fix on exisiting PCC pole with nuts and bolts for 1* 1/2" dia GI pipe bracket including tools and plants such as Ghori, etc	4	each	459	1836
4.	Dismantling and re-erection of exisiting street light fitting including GI pipe bracket, clamp and erection testing, commissioning of LED street light fitting on other blank poles including tools and plants such as Ghori etc.	3	each	500	1500
5.	Supply installation testing and commissioning of thermo plastic cable junction box 1P55 of sixe 155*210*92mm deep approximate with 4 nos terminal blocak suitable for 1 no incoming and 3 nos outgoing cables for erection of LED street light fitting. The terminal black shall be made of Hansel/Legrand/Hylec/Clipsal only and cable junction box of make Hansel/Legrand/Hylec/Clipsal only. The Job includes all labour and petty material required to complete the job to the entire satisfaction of the engineer in charge.		each	2100	8400
	Total				79512
-	Rate to be quoted by the contractor	%less/Above			

Conditions:

- 1. The work shall be carried out according to CPWD General Specifications.
- 2. No claim on account of fluctuation in prices due to any reason shall be considered.
- 3. The quantity can be increased or decreased as per actual requirement at site.
- No premium will be allowed on M.R. Items, abatement, if any shall be applicable on all items including market rates.
- 5. Any error or omission in nomenclature or unit can be corrected at any stage.
- 6. The quality of material shall be strictly in accordance with the specification given in DNIT.
- 7. All the material shall be inspected by the Engineer-in-charge before installation at site.
- The department has reserve the right to issue any amendment to the work order as emergency demands or allow of altogether cancel the contract without assigning any reason. The Deptt. Reserves the right to delete any item.

9. Discount offered by the firm should also be considered in additional/ extra DSR/ MR Items, if the rate quoted are lesser than the DNIT amount.

10. The firm shall quote the rates inclusive all the taxes/ GST whatever required and no extra payment

shall be made in this respect.

11.

A	Piano type accessories	Anchor/Anchor Penta/ Havells Reo/ Gold Medal Essenza
В	Modular type accessories/sheets/boxes	Legrand (Arteor)/Schneider (Zencelo)/Crabtree (Murano)/ L&T (Englaze/ MK(Elements)/ABB (Cheiron)/ Gold Medal(GIFA)
С	PVC batten/Conduit pipe (ISI marked)	Polycab/Diplast/AKG/Polyplast
D	PVC copper wires FRLS (ISI Marked)	Polycab/L&T/Havells/ Finolex/R.R. Kables
Е	MCB's/RCCB's/ELCB's	L&T (Exora)/ Legrand (DX3)/ Hager (H3)/ /Schneider (Acti-9)/ ABB (SH200M)/ Siemens (Betagard)/Havells
F	BDB's/ A.C. Plug. Socket	L&T/Legrand/Hager//Schneider/Siemens/ABB/Havells
G	GI Pipe ISI Marked	Jindal Hissar/ Tata

Endst. No. 2708-10

Copy of the above is forwarded to the following:

1. Chairman Estate & Works

2. Webmaster, with a request to upload on the Institute website

3. Notice Board

University Engineer

Date

0 8 FEB 2022