

Punjab Engineering College, Sector-12, Chandigarh
(Deemed to be University)

No. PEC/EO/2022-23/926-928

Dated: 11/10/22

Notice Inviting Quotations

Sealed Quotation are hereby invited on behalf of Director, Punjab Engineering College, Sector-12, Chandigarh on percentage rate basis for the following work and will be opened in the office of the undersigned on dated 18.10.2022 at 3:30 p.m. The quotations will be received on or before 18.10.2022 upto 3:00 p.m. The bidder must be enlisted with Chandigarh Administration in the relevant category.

Name of Work: - Providing and fixing of exhaust fans in particulate laboratory MMED Deptt at Punjab Engineering College, Sector-12, Chandigarh.

SCHEDULE OF WORK

SLNo	Description	Qty	Unit	Rate	Amount
1	Wiring for circuit/ submain wiring alongwith earth wire with the following sizes of FRLS PVC insulated copper conductor, single core cable in surface/ recessed medium class PVC conduit as required.				
2	2 X 1.5 sq. mm + 1 X 1.5 sq. mm earth wire	14	Metre	233.00	3262.00
3	Supplying and fixing following modular switch/ socket on the existing modular plate & switch box including connections but excluding modular plate etc. as required.				
4	5/6 A switch	2	Each	103.00	206.00
5	Supplying and fixing following size/ modules, GI box alongwith modular base & cover plate for modular switches in recess etc. as required.				
6	1 or 2 Module (75mmX75mm)	1	Each	298.00	298.00
7	Supplying and fixing 3 pin, 5 A ceiling rose on the existing junction box/ wooden block including connections etc. as required.	2	Each	87.00	174.00
8	Providing and fixing of MS sheet frame of size 0.85mtr x 0.85mtr made of 14SWG thick sheet (2mm) duly molded all around, hole cutting for exhaust fan 450mm sweep and duly coating of approved paint. The job includes fixing of frame on existing window with petty material and labour required to complete the job in all respect.	2	Each	3867.00	7734.00
9	Supply and erection of exhaust fan metallic body, Size 18" sweep 900 RPM complete in all respect with necessary connections. The job includes Installation of exhaust fan in the existing opening, including making good the damage, connection, testing, commissioning etc. as required. Makes:- Havells- turbo force SP/crompton- EXHD 300-6-1/Bajaj-Supreme DLX.	2	Each	7511.00	15022.00

10	Supply and erection of National make louver shutter with aluminum wings for exhaust fan of size 450mm on existing hole complete with petty material and labour required to complete the job.	2	Each	1284.00	2568.00
	Total				29264.00

Rate to be quoted by the contractor _____ %less/Above

Conditions:

1. The work shall be carried out according to CPWD General Specifications.
2. No claim on account of fluctuation in prices due to any reason shall be considered.
3. The quantity can be increased or decreased as per actual requirement at site.
4. No premium will be allowed on M.R. Items, abatement, if any shall be applicable on all items including market rates.
5. Any error or omission in nomenclature or unit can be corrected at any stage.
6. The quality of material shall be strictly in accordance with the specification given in DNIT.
7. All the material shall be inspected by the Engineer-in-charge before installation at site.
8. The department has reserve the right to issue any amendment to the work order as emergency demands or allow of altogether cancel the contract without assigning any reason. The Deptt. Reserves the right to delete any item.
9. Discount offered by the firm should also be considered in additional/ extra DSR/ MR Items, if the rate quoted are lesser than the DNIT amount.
10. The firm shall quote the rates inclusive all the taxes/ GST whatever required and no extra payment shall be made in this respect.
- 11.

List of approved makes are as under		
A	Piano type accessories	Anchor/Anchor Penta/ Havells Reo/ Gold Medal Essenza
B	Modular type accessories/sheets/boxes	Legrand (Arteor)/Schneider (Zencelo)/Crabtree (Murano)/ L&T (Englaze/ MK(Elements))/ABB (Cheiron)/ Gold Medal(GIFA)
C	PVC batten/Conduit pipe (ISI marked)	Polycab/Diplast/AKG/Polyplast
D	PVC copper wires FRLS (ISI Marked)	Polycab/L&T/Havells/ Finolex/R.R. Kables
E	MCB's/RCCB's/ELCB's	L&T (Exora)/ Legrand (DX3)/ Hager (H3)/ /Schneider (Acti-9)/ ABB (SH200M)/ Siemens (Betagard)/Havells
F	BDB's/ A.C. Plug. Socket	L&T/Legrand/Hager//Schneider/Siemens/ABB/Havells
G	GI Pipe ISI Marked	Jindal Hissar/ Tata

University Engineer

Copy of the above is forwarded to the following:

1. Chairman Estate & Works
2. Webmaster, with a request to upload on the Institute website
3. Notice Board

University Engineer