

# Punjab Engineering College, Sector-12, Chandigarh (Deemed to be University)

No. PEC/2026/753

Dated: 24.04.26

## Notice Inviting Quotations

Sealed Quotations are hereby invited by the undersigned on behalf of the Director, Punjab Engineering College, Secor-12, Chandigarh on percentage rate basis for the following work and will be opened in the office of the undersigned on dated 27.04.2026 at 3:30 P.M. The quotations will be received up to 3:00 P.M on 27.04.2026. The bidder must be enlisted with Chandigarh Administration in the relevant category (Electrical Work)

**Name of Work: Repair & modification of AMF panel of DG Set**

### SCHEDULE OF QUANTITIES

S. No.	Description of Items	Qty.	Unit	Rate	Amount
1	SITC of 2 no. of LK make MCX 45, 4 Pole 600 amp. Contactor, two glass relay with base in the existing AMF panel of DG Set including the cost of removal old contactors and installation of new with bus bar modification of requisite capacity. The job includes the cost of all petty material and labour required for. Termination of cable and testing of the AMF panel for its working to the entire satisfaction of Engineer- In Charge	1	Job	1,87,804/-	1,87,804/-
	Total				<b>1,87,804/-</b>
<b>Rupees One lac eighty seven thousand eight hundred four only</b>					
<b>Rate to be quoted by the bidder</b>				<b>% below/ Above</b>	

### Term & Conditions

1	No Claim will be entertained from the contractor in case of error in description, rates units taken by the department in the schedule of quantity & price bid during preparation on account of typing, that of comparison or over sighting, if there will be any mistake that will be rectified at any stage as per DSR 2022 by the Engineer-in-charge.
2	The quantity given against each item in the schedule can be increased or decreased by the Engineer-in-charge at any time, no objection of any claim from the contractor will be entriained on this account.
3	Although various makes have been mentioned against each items for inviting the healthy competition, but material selection i.e. makes of the material to be installed will be decided by the department and agency has to bring the same at site. Therefore, agencies are requested to quote the rate accordingly and further it is made clear that no financial deviation/ benefit will be entertained by the department on the basis of the material brought at site as per direction of department later on.
4	Before the start of work, the agency has to bring samples of all the material of the approved make to be used at site and get it approved from the E.I.C. Only approved material and make will be allowed to be used at site.
5	Any material of the approved make if not available / manufactured then equivalent specification material of any other make may be allowed subject to approval of EIC.
6	The Electrical work shall have to be executed side by side with Civil and PH work.
7	Separate colour of wires shall be used for phase and neutral so as to distinguish it for live conductor.
8	All the cables/wires connections should be done through lugs/thimbles duly crimped with proper crimping tools & no extra payment shall be made on this account.
9	The rate quoted by the bidder shall be inclusive of all taxes etc., nothing extra will be paid on any other account.

University Engineer  
Dated

Endst. No. PEC/EO/

Copy of the above is forwarded to the following:

1. Webmaster, to upload on institute website.
2. Notice Board

University Engineer